

**NAPA-SOLANO-YOLO-MARIN COUNTY
PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
PHONE: 707-784-4410 FAX: 707-423-1979
DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: BMK

Bel Marin Keys
4 Montego Key
NOVATO, CA 94949

CONTACT: N/A
PH: (415) 883-4222 FAX:

LOCATION: 4 Montego Key, Bel Marin Keys CSD
C/O:

COUNTY: Marin
PHONE:

LAB #: 25W1192
COLLECTED BY: B. Clark
SAMPLING POINT: Calypso Ramp, N. Lagoon

TEMPERATURE 4.5 C
AT RECEIPT:

DATE COLLECTED: 6/9/2025 10:10 AM
DATE RECEIVED: 6/9/2025 3:06 PM
TREATED:
CHLORINE (PPM):
PH:

TEST REQUESTED

RESULTS

UNITS

1:10 Colilert Quantitray

Total Coliform (1:10)

3873.0

MPN per 100 mL of water

Escherichia coli (1:10)

<10

MPN per 100 mL of water

Date/Time of Incubation

6/9/25 @ 1535

Quantitray comment

Total coliform testing of recreational water was performed using IDEXX Colilert which is not an EPA-approved Clean Water Act Microbiological Test Method. Local government agencies with historical total coliform monitoring data desire continued testing of total coliforms to indicate water quality. The total coliform test was performed at the request of the submitting agency.

Method (Water)

SM 9223 B-2016 Colilert 18

1:10 Enterolert Quantitray

Enterolert

<10

MPN per 100 mL of water

Date/Time of Incubation

6/9/25 @ 1535

Method (Water)

SM 9230 D-2013 Enterolert

**NAPA-SOLANO-YOLO-MARIN COUNTY
PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
PHONE: 707-784-4410 FAX: 707-423-1979
DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: BMK

Bel Marin Keys
4 Montego Key
NOVATO, CA 94949

CONTACT: N/A
PH: (415) 883-4222 FAX:

LOCATION: 4 Montego Key, Bel Marin Keys CSD
C/O:

COUNTY: Marin
PHONE:

LAB #: 25W1193
COLLECTED BY: B. Clark
SAMPLING POINT: Calvert, S. Lagoon

TEMPERATURE 4.5 C
AT RECEIPT:

DATE COLLECTED: 6/9/2025 10:02 AM
DATE RECEIVED: 6/9/2025 3:05 PM
TREATED:
CHLORINE (PPM):
PH:

TEST REQUESTED

RESULTS

UNITS

1:10 Colilert Quantitray
Total Coliform (1:10)
Escherichia coli (1:10)
Date/Time of Incubation
Quantitray comment

11199.0
111.0
6/9/25 @ 1535
Total coliform testing of recreational water was performed using IDEXX Colilert which is not an EPA-approved Clean Water Act Microbiological Test Method. Local government agencies with historical total coliform monitoring data desire continued testing of total coliforms to indicate water quality. The total coliform test was performed at the request of the submitting agency.

MPN per 100 mL of water
MPN per 100 mL of water

Method (Water)

SM 9223 B-2016 Colilert 18

1:10 Enterolert Quantitray
Enterolert
Date/Time of Incubation
Method (Water)

780.0
6/9/25 @ 1535
SM 9230 D-2013 Enterolert

MPN per 100 mL of water

**NAPA-SOLANO-YOLO-MARIN COUNTY
PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
PHONE: 707-784-4410 FAX: 707-423-1979
DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: BMK

Bel Marin Keys
4 Montego Key
NOVATO, CA 94949

CONTACT: N/A
PH: (415) 883-4222 FAX:

LOCATION: 4 Montego Key, Bel Marin Keys CSD
C/O:

COUNTY: Marin
PHONE:

LAB #: 25W1194
COLLECTED BY: B. Clark
SAMPLING POINT: Bahama Reef Ramp, S. Lagoon

TEMPERATURE 4.5 C
AT RECEIPT:

DATE COLLECTED: 6/9/2025 10:06 AM
DATE RECEIVED: 6/9/2025 3:07 PM
TREATED:
CHLORINE (PPM):
PH:

TEST REQUESTED

RESULTS

UNITS

1:10 Colilert Quantitray
Total Coliform (1:10)
Escherichia coli (1:10)
Date/Time of Incubation
Quantitray comment

2382.0
20.0
6/9/25 @ 1535
Total coliform testing of recreational water was performed using IDEXX Colilert which is not an EPA-approved Clean Water Act Microbiological Test Method. Local government agencies with historical total coliform monitoring data desire continued testing of total coliforms to indicate water quality. The total coliform test was performed at the request of the submitting agency.

Method (Water) SM 9223 B-2016 Colilert 18

MPN per 100 mL of water
MPN per 100 mL of water

1:10 Enterolert Quantitray
Enterolert
Date/Time of Incubation
Method (Water)

<10
6/9/25 @ 1535
SM 9230 D-2013 Enterolert

MPN per 100 mL of water